

01/03/2017-3:57		Porter Creek Subdivision	Construction mud in road.	Paul Smith	Site visit- property owner will clean road.
01/05/2017-11:14		Somerset	No silt fence or CO	Gaby Bryan	Site visit -Construction crew cleaned road.
01/18/2017-9:15		6551 Hog Mt. Road	Clearing w/o permit.	Gaby Bryan	Site visit-Builder is applying for permits required.
01/23/2017-10:07		Charlotte's Walk	House being constructed w/o silt fence.	Paul Smith	Site visit- Builder will install drainage ditch on property line.
01/23/2017-11:40	Craig	1560 Rocky Branch Rd.	Loggers bringing mud into road.	Paul Smith	Site visit-road clean- advised on plan to keep road clean.
01/23/2017-11:40	Craig	1560 Rocky Branch Rd.	Loggers bringing mud into road.	Paul Smith	Site visit-road clean- advised on plan to keep road clean.
02/06/2017-10:55		Boulder Springs Drive	No silt fence on construction site.	Paul Smith/Gaby Bryan	Site visit- Builders installed silt fence.
02/28/2017-8:35	Karen Russell	1355 Cold Tree	Internet Contractor left mud in road.	Paul Smith	Site visit- Contractor cleaned all areas.
02/28/2017-9:20	Donna Norton	Malcom Bridge Rd.	Demobilised barn & mobile Home	Gaby Bryan	Site visit-Advised to seed & straw disturbed areas.
03/14/2017-9:20		Cliff Dawson- Mulky Property	Mud in Road	Paul Smith	Site visit- Crew cleaned road/
03/16/2017-12:15	Ron Walpert	Old Farm-Cliff Dawson Rd.	Lot disturbed-no silt fence in 25' Water Buffer	Paul Smith	Builder will install silt fence-remove small growth from Buffer first.
03/30/2017-4:16	Eric Simpson	1041 Vanessa Drive	Purple Paint dumped down storm drain	Gaby Bryan	Site visit- Person responsible to clean up paint debris.
04/03/2017-1:50		Somerset- Wade Drive	Soil Erosion problem-first tw houses on Wade Drive.	Paul Smith	Site visit- advised Builder to install BMP's for problem.
04/03/2017-3:30	Hatcher	1740 Whipporwill Rd.-Robinson Creek	Creek water blackish color -raining	Paul Smith	Site visit- unable to determine source- creek cleared.
04/05/2017-2:12	Michael Wayne	Meadow Springs-Cliff Dawson Road	Mud in road from construction site.	Paul Smith	Site visit- builder removing mud.
04/05/2017-3:00	Jason	2370 Hog Mt. Rd.	Storm debris washed from neighbor's property.	Paul Smith	Site visit- call Bill Bath for cleanup and solution.
04/06/2017-1:57	Drew Dekle	1020 White Oak Drive	Erosion causing dirt to enter Oconee River	Paul Smith	Site visit- cleaned out silt fence-will instal curbing and straw bales to reduce water runoff.
04/13/2017-8:00	Lake Welbrook HOA	1631 Welbrook Rd.	Water & Sediment coming off property.	Gaby Bryan	Site visit- Builder's to install silt fence for erosion control.
04/20/2017-8:00	Angela-Parker & Assoc	1866 Meadow Springs Drive	Silt fence failure-water crossing rear yard.	Gaby Bryan	Site visit-Builder to repair silt fence-water private issue.
04/20/2017-8:46	Anty	Lea Haven-Lot 10 or 11	Possible soil erosion problem	Paul Smith	Site visit- Builder will install silt fence prior to disturbance.
05/24/2017-10:29		Surry Ridge Dr./ Williams Downs	Mud in road from construction	Paul Smith	Site visit- Builder's advised to clean road.
05/31/2017-8:52	Britt Richards	William Downs Subdivision	Construction crew leaving mud in road.	Paul Smith	Site visit- called Builders and advised to clean road.
06/16/2017-2:30	BR White	1171 Plantation Dr.	Possible sediment leaving construction site.	Paul Smith	Site visit- No problems observed- silt fence & CO installed, Road clean.
07/11/2017-12:05	Rama	1125 Orchard Dr.-Meadow Springs	Construction activity on adjacent property resulting in sedimentation problem for Meadow Springs.	Gaby Bryan	Site visit- property owner to make corrective action.
08/03/2017-9:05		Planter's Ridge Dr.-Planter's Ridge	Builder not installing BMP's on construction site.	Paul Smith	Site visit-advised Builder to install BMP's
8/14/17-9:17	Ga Soil and water conservation	Lane Creek Subdivision	Mud in rd & Black fence down	Gaby	Cleaned Road- Maintenance on silt fence
8/9/2017	BR White	Dove Creek Elementary School	No Soil Erosion	Gaby	Soil Erosion measures have been installed
10-09-2017	Todd Landers	1010 Bouldercrest Circle	Mud running off construction site	Gaby	Contractor corrected issues with Silt Fence and Straw.
10-24-2017	Michael Weathers	Cliff Dawson Road	Mud tracked	Gaby	Contractor working to correct issue
11-08-2017	Cheryl O. Bond	Osborne Road	Concrete being poured into creek, milky	Gaby	evidence not observed, contractor advised they did not wash trucks on site.
11-14-2017	Liz Smith	Whipporwill Road	Mud in roadway.	Gaby	Evidence of complaint not found.
12-07-2017	Richard D. Wiley	1842 Fairfield Ave	Mud on roadway due to new construction	Bowman	Area cleaned.
12/18/2017	Linda Basham	3519 Orchard Circle	Mud in the road	Gaby	Cleaned Road
12/20/2018	Linda Basham	3519 Orchard Circle	Mud leaving site	Gaby	installed silt fence